

Pool Electrical Bond Inspection Checklist

This checklist is not to be construed as all-inclusive; it is only to be used as a guideline.

CODE ITEM	CODE	SECTION
Grounding with minimum #8 ground wire around deck with ground clamps and all metal within 5'	2014 NEC	680.26
Grounding of copper conduit for pool lights/fixtures	2014 NEC	680.23
Position of plugs in relation to pool sides	2014 NEC	680.22
Low voltage lighting/transformer ground run to equipment ground to panel	2014 NEC	680.24