

HVAC Work Final Inspection Checklist

This checklist is not to be construed as all-inclusive; it is only to be used as a guideline.

CODE ITEM	CODE	SECTION
Gas appliance, connectors	2015 IFGC	411
Vent installation	2015 IMC	802
Vent termination	2015 IMC	802
Gas shut-off valves	2015 IFGC	409
Factory labels	2015 IMC	301
Accessibility	2015 IMC	306
Condensate disposal	2015 IMC	307
Protection from damage	2015 IMC	302
Return mounted shutdown smoke detectors	2015 IMC	606
Roof access	2015 IMC	306
Controls/temperature	2015 IMC	309
Elevation of ignition source	2015 IMC	304.3