Pool Electrical Bond Inspection Checklist

This checklist is not to be construed as all-inclusive; it is only to be used as a guideline.

CODE ITEM	CODE	SECTION
Grounding with minimum #8 ground wire around deck with ground clamps and all metal with 5'	2011 NEC	680-26
Grounding of copper conduit for pool lights/fixtures	2011 NEC	680-23
Position of plugs in relation to pool sides	2011 NEC	680-22
Low voltage lighting/transformer ground run to equipment ground to panel	2011 NEC	680.24