



**2015 IECC PERFORMANCE  
TESTING COMPLIANCE  
CERTIFICATE**

Job Address: \_\_\_\_\_ Date: \_\_\_\_\_  
Permit Number: \_\_\_\_\_

**BUILDING THERMAL ENVELOPE LEAKAGE TESTING VERIFICATION**

**Compliance requirements:** per 2015 IECC Section R402.4.1.2, building thermal envelope tested @ 50 Pascals in accordance with ASTM E 779 or ASTM E1827 to verify air leakage.

**Building Thermal Envelope Leakage Testing:** Results of test: \_\_\_\_\_ air changes per hour.

I certify that I have conducted an **air leakage test and it has passed the requirements of the 2015 International Energy Conservation Code**. I further certify that I am certified to perform air infiltration testing certified by national or state organizations as approved by the building official. I certify I am an independent third-party entity, nor am I employed or have any financial interest in the company that constructs the structure.

Certification Number: Agency: \_\_\_\_\_  
Signature of Inspector/Testing Technician: \_\_\_\_\_  
Printed Name of Inspector/Testing Technician: \_\_\_\_\_

**DUCT LEAKAGE TESTING VERIFICATION**

**Choose option used for compliance:** per 2015 IECC Section R403.3.4, system tested @ 25 Pascals across, including the manufacturer's air handler enclosure.

- Rough-In Test Option** (see code for test specifics): Results of test: \_\_\_\_\_ CFM.
- Post Construction Option** (see code for test specifics): Results of test: \_\_\_\_\_ CFM.

I certify that I have conducted a **duct blaster test and it has passed the requirements of the 2015 International Energy Conservation Code**. I further certify that I am certified to perform duct testing leakage testing certified by national or state organizations as approved by the building official. I certify I am an independent third-party entity, and have not installed the HVAC system; nor am I employed or have any financial interest in the company that constructs the structure.

Certification Number: Agency: \_\_\_\_\_  
Signature of Inspector/Testing Technician: \_\_\_\_\_  
Printed Name of Inspector/Testing Technician: \_\_\_\_\_