

Fire Lane Inspection Checklist

This checklist is not to be construed as all-inclusive; it is only to be used as a guideline.

CODE ITEM	CODE	SECTION
Soil engineer and lab	GDS (Paving)	2.A.1
Hydrated lime treatment	GDS (Paving)	2.0.1
Density 95% of maximum dry density Proctors: ASTM D698	GDS (Paving)	2.P.A
Concrete mixtures and testing	GDS (Paving)	2.D
Concrete thickness	GDS (Paving)	2.D.8
Reinforcing Fire lanes #3 bars @ 18" o.c.	GDS (Paving)	P-20
Fire lanes 24 feet clear width Marking	GDS (Paving)	P-20