

Water Meter Pre- Install Inspection Checklist

This checklist is not to be construed as all-inclusive; it is only to be used as a guideline.

CODE ITEM	CODE	SECTION
1" and smaller meter loop furnished by contractor. Top of meter to be not less than 9" or more than 12" below top of meter can. Meter can set on loop. Bass & Hayes P 34P 14 D can	GDS	W-7 1 of 1 Pg. 4-9
1 1/2" and larger meters curb stop 22"- 26" below top of curb	GDS	W 7-1
No right angle curb stops	GDS	W 7-1
3' circumference around curb stop	GDS	W 7-1
Meter not in paving area	City Policy	
Correct meter can next to installation Bass & Hayes P548P 18D can	GDS	Pg. 4-9