



CARROLLTON  
TEXAS

DAILY INSPECTION RESULTS  
As of Tuesday, October 08, 2019 12:00 PM

Permit Number	Phone Sys. Num.	Street Address	Inspection Code - Description	Insp. Num.	Inspector Name	Inspection Results	Inspection Result Comment
PR17-1769	1010	4421 Charles St, Carrollton, Tx 75010	PRC200042 - Electrical Service	2800	David C. Garcia	Passed w/ Conditions	1.electrical service underground
PR17-7321	3040	1700 W Frankford Rd, Carrollton, Tx 75007	PRC200025 - Building Framing-Commercial	951	Reynaldo Guerrero	Partial Pass	clubhouse ok only
PR18-4470	1053	4060 Sh 121, Carrollton, Tx 75010	PRC200077 - Paving Onsite-Commercial	6303	Reynaldo Guerrero	Partial Pass	fire lane off of sh 121
PR18-6287	2010	2395 Midway Rd, Carrollton, Tx 75006	PRC200116 - Underfloor Electrical	10501	David C. Garcia	Passed	
PR18-7478	1902	1830 W Belt Line Rd	PRC200093 - Pre-Pour/Foundation-Commercial	7903	Reynaldo Guerrero	Failed	unable to access site
PR18-7624	1085	2080 Mc Daniel Dr, Carrollton, Tx 75006	PRC200132 - Real Estate Sign Final	12500	Sysadmin	Pending	REAL ESTATE SIGN FINAL INSPECT: Inspection Comment - permit expires 10/2/19
PR18-7657		1425 Whitlock Ln, Carrollton, Tx 75006	PRC200132 - Real Estate Sign Final	12500	Sysadmin	Pending	REAL ESTATE SIGN FINAL INSPECT:
PR18-7659		1325 Whitlock Ln, Suite:101, Carrollton, Tx 75006	PRC200132 - Real Estate Sign Final	12500	Sysadmin	Pending	REAL ESTATE SIGN FINAL INSPECT:
PR18-7660		1325 Whitlock Ln, Suite:101, Carrollton, Tx 75006	PRC200132 - Real Estate Sign Final	12500	Sysadmin	Pending	REAL ESTATE SIGN FINAL INSPECT:
PR18-7742	4063	4540 Sir Craig Dr, Carrollton, Tx 75056	PRC200023 - Building/Energy Final-Residential	900	Shaun Everett	Passed	
PR18-9635	3040	1725 Sandy Lake Rd, Carrollton, Tx 75006	PRC200025 - Building Framing-Commercial	950	Reynaldo Guerrero	Partial Pass	warehouse and office ok
	4010		PRC200029 - Electrical/Energy Final-Commercial	2	Reynaldo Guerrero	Partial Pass	warehouse ok
	1075		PRC200109 - Swppp	9700	Reynaldo Guerrero	Partial Pass	
PR19-1526	4063	4524 St. Samon's St, Carrollton, Tx 75056	PRC200023 - Building/Energy Final-Residential	901	Shaun Everett	Passed	Missing Energy stamp on breaker box in garage
PR19-2097	4007	2537 Bozeman Ln, Carrollton, Tx 75010	PRC200112 - Termite Protection Certificate	10000	Lisa Cheek	Passed	
PR19-436	1010	3050 N Josey Ln, Carrollton, Tx 75007	PRC200042 - Electrical Service	2800	David C. Garcia	Failed	1.no bushings at service raceways 2.no anti-oxidant/noalox at aluminum feeder wires 3.not ready
PRAS201905833	3066	4501 St. Samon's St, Carrollton, Tx 75056	PRC200022 - Building (Framing)-Residential	800	Shaun Everett	Passed	
PRAS201905990		1200 Valwood Pkwy, Carrollton, Tx 75006	PR00014 - Foundation/Engineer's Letter	500	Alexandra Choung	Passed	



CARROLLTON  
TEXAS

DAILY INSPECTION RESULTS  
As of Tuesday, October 08, 2019 12:00 PM

Permit Number	Phone Sys. Num.	Street Address	Inspection Code - Description	Insp. Num.	Inspector Name	Inspection Results	Inspection Result Comment
PRAS201906632	4063	2030 Clubview Dr, Carrollton, Tx 75006	PRC200023 - Building/Energy Final-Residential	900	Reynaldo Guerrero	Passed	
	4040		PRC200026 - Building/Energy Final-Commercial	1200	Ed Green	VOID	
PREL201905645	3010	1902 Kirkwood Cir, Carrollton, Tx 75006	PRC200105 - Solar Panel Electrical Rough	9300	David C. Garcia	Passed w/ Conditions	1.need pictures of grounding at point of attachment on rail and interior of j-box 2.emt on roof not labeled 3.emt on roof not secured 4.make corrections and send photos for approved Final Inspection
PREL201906860	1010	1756 Castille Dr, Carrollton, Tx 75007	PRC200042 - Electrical Service	2800	David C. Garcia	Passed w/ Conditions	1.bond screw not in contact with threads of nipple
PREL201907072		1804 E Belt Line Rd, Carrollton, Tx 75006	PRC200042 - Electrical Service	2800	Reynaldo Guerrero	Failed	no answer at door
PRFN201906602	1090	4424 Fairway Dr, Carrollton, Tx 75010	PRC200044 - Fence	3000	Shaun Everett	Passed	
PRMH201905624	4004	1945 Kentwood Ln, Carrollton, Tx 75007	PRC200062 - Hvac/Energy Final-Residential	4801	Hermilo Balderas	Passed	
PRMH201905998		1432 Greenway Park Dr, Carrollton, Tx 75007	PRC200062 - Hvac/Energy Final-Residential	4800	Shaun Everett	Passed	
PRRN201904326	3067	3625 Foxboro Ln, Carrollton, Tx 75007	PRC200065 - Insulation/Envelope Seal	5101	Shaun Everett	Passed	
PRRN201905146	3034	3733 N Josey Ln, Suite:103, Carrollton, Tx 75007	PRC200031 - Hvac Rough/Insulation-Commercial	1701	Reynaldo Guerrero	Passed	
PRRN201905698	4010	2500 Guerrero Dr, Carrollton, Tx 75006	PRC200029 - Electrical/Energy Final-Commercial	5	David C. Garcia	Passed	
	4030		PRC200032 - Hvac/Energy Final-Commercial	1805	David C. Garcia	Passed	
PRRN201906169	3040	3000 Kellway Dr, Suite:140	PRC200025 - Building Framing-Commercial	950	Reynaldo Guerrero	Passed	
PRSF201902834	4063	4541 St. Samon's St, Carrollton, Tx 75056	PRC200023 - Building/Energy Final-Residential	901	Reynaldo Guerrero	Passed	
PRSF201903545	3064	4508 St. Samon's St, Carrollton, Tx 75056	PRC200040 - Electrical Rough/Energy-Residential	2600	Shaun Everett	Failed	Missing ground screws in metal ceiling fan boxes, ground screw at electric panel needs to be tightened
	3063		PRC200061 - Hvac Rough/Energy-Residential	4700	Shaun Everett	Passed	
PRSF201905832	1028	4421 Tall Knight Ln, Carrollton, Tx 75056	PRC200124 - Water Meter Pre-Installation R.O.W.	11300	Shaun Everett	Passed	Remove water from around loop



**CARROLLTON**  
TEXAS

## DAILY INSPECTION RESULTS

As of Tuesday, October 08, 2019 12:00 PM

Permit Number	Phone Sys. Num.	Street Address	Inspection Code - Description	Insp. Num.	Inspector Name	Inspection Results	Inspection Result Comment
PRSG201905000	4041	1060 W Frankford Rd, Suite:208, Carrollton, Tx 75007	PRC200102 - Sign Final W/Electrical/Elec. Incl. If Any	9001	Reynaldo Guerrero	Failed	not installed
PRSG201906450		3030 N Josey Ln, Suite:147, Carrollton, Tx 75007	PRC200102 - Sign Final W/Electrical/Elec. Incl. If Any	9000	Reynaldo Guerrero	Failed	not installed