



**CARROLLTON**  
TEXAS

**DAILY INSPECTION RESULTS**  
As of Tuesday, October 26, 2021 12:00 PM

Permit Number	Phone Sys. Num.	Street Address	Inspection Code - Description	Insp. Num.	Inspector Name	Inspection Results	Inspection Result Comment
PRAD202105710	3066	2125 Nolan Dr, Carrollton, Tx 75006	PRC200022 - Building Framing-Residential	2001	David C. Garcia	Failed	1.no answer at door - no access
	3064		PRC200040 - Electrical Rough/Energy-Residential	1601	David C. Garcia	Failed	1.no answer at door - no access
	4062		PRC200041 - Electrical/Energy Final-Residential	3201	David C. Garcia	Failed	1.no answer at door - no access
PRBD202003610	7500	1714 Lady Bettye Dr	PRC200090 - Pre-C.O. Inspection & Meeting	10600	Hermilo Balderas	Failed	1. Bathroom need labels 2. Gate needs emergency/panic bar. Refer to the pool permit Pool Enclosure detail notes. 3. GFCI outlet on exterior building needs label 4. Cover plate on data box 5. Access panel needs to be labeled for use
			PRC200171 - Swppp - S.O.P. Final	5101	Hermilo Balderas	Passed	
PRBD202007511	8000	1012 Mac Arthur Dr, Carrollton, Tx 75007	PRC200091 - Pre-Construction Meeting	10900	Lisa Cheek	Passed	
PRBD202101621	2025	4305 Marsh Ridge Rd, Carrollton, Tx 75010	PRC200078 - Plumbing Rough/Setback/Energy-Commercial	700	Gregory Smith	Passed w/ Notes	Pictures of pressure test emailed. Please upload any pictures and/or necessary documents to your permit in the future.
PRBD202101624		4309 Marsh Ridge Rd, Carrollton, Tx 75010	PRC200078 - Plumbing Rough/Setback/Energy-Commercial	701	Gregory Smith	Passed w/ Notes	Pictures of pressure test emailed. Please upload any pictures and/or necessary documents to your permit in the future.
PREL202106886	4062	2042 Wildrose, Carrollton, Tx 75007	PRC200041 - Electrical/Energy Final-Residential	3200	David C. Garcia	Not Ready	1.canceled by contractor
PREL202106931	6015	2601 N Josey Ln, Carrollton, Tx 75007	PRC200038 - Electrical Service/Construction Heat/Clean & Show	2600	Michael Serna	Passed	
PRFN202105475	1090	2100 Nob Hill, Carrollton, Tx 75006	PRC200044 - Fence	6802	Michael Serna	Passed	
PRFN202105661		1823 Appletree Ln, Carrollton, Tx 75006	PRC200044 - Fence	6800	Michael Serna	Not Ready	
PRFN202105670		2015 Alsace Dr, Carrollton, Tx 75007	PRC200044 - Fence	6900	Michael Serna	Passed	
PRFN202105759		2009 Meadfoot Rd, Carrollton, Tx 75007	PRC200044 - Fence	6801	Michael Serna	Not Ready	
PRFN202106055		1731 Delaford Dr, Carrollton, Tx 75007	PRC200044 - Fence	6900	Thomas Schenkelberg	Passed	
PRMH202104972	4030	2305 E Belt Line Rd, Carrollton, Tx 75006	PRC200032 - Hvac/Energy Final-Commercial	3301	Michael Serna	Passed	
PRMH202105576	4004	4280 Kiowa Dr, Carrollton, Tx 75010	PRC200062 - Hvac/Energy Final-Residential	3400	Reynaldo Guerrero	Passed	



**CARROLLTON**  
TEXAS

**DAILY INSPECTION RESULTS**  
As of Tuesday, October 26, 2021 12:00 PM

Permit Number	Phone Sys. Num.	Street Address	Inspection Code - Description	Insp. Num.	Inspector Name	Inspection Results	Inspection Result Comment
PRMH202106109	4030	2305 E Belt Line Rd, Carrollton, Tx 75006	PRC200032 - Hvac/Energy Final-Commercial	3301	Michael Serna	Passed	
PRMH202106597	4004	2504 Canterbury Dr, Carrollton, Tx 75006	PRC200062 - Hvac/Energy Final-Residential	3400	Reynaldo Guerrero	Passed	
PROA202106701	4064	1625 Crescent Cir, Suite:314, Carrollton, Tx 75006	PRC200076 - Occupancy Application: O.A.; Sign/Zoning/Construction Code Final	9500	David C. Garcia	Failed	1.label panels and all breakers 2.remove unused FLMC from panel - add ko plug 3.Rack system being installed in warehouse - permit required 4.fenced storage area on premises no permit on file 5.unable to locate electrical meter base
PROA202106703		1620 N Ih 35E Hwy, Carrollton, Tx 75006	PRC200076 - Occupancy Application: O.A.; Sign/Zoning/Construction Code Final	9500	David C. Garcia	Failed	1.new water heater & other work done - no permit on file
PROA202106704		1017 E Trinity Mills Rd, Suite:110, Carrollton, Tx 75007	PRC200076 - Occupancy Application: O.A.; Sign/Zoning/Construction Code Final	9500	David C. Garcia	Passed	
PROA202106845		2410 Luna Rd, Carrollton, Tx 75006	PRC200076 - Occupancy Application: O.A.; Sign/Zoning/Construction Code Final	9500	Michael Serna	Passed	
PRPL202106612	1036	3720 Cromwell Dr, Carrollton, Tx 75007	PRC200000 - Plumbing Work Final	13000	Gregory Smith	Not Ready	Must upload pictures of the work that was done for inspection, along with a completed Photo/Video Cert form and an Under Slab Backfill letter. If you have any questions about this, contact a Permit Tech at our service desk. Thank you.
PRPL202106728	1034	3128 Fairgate Dr, Carrollton, Tx 75007	PRC200148 - Under Slab Excavation/Backfill Verification	9800	Gregory Smith	Failed	Must have a completed Under Slab Backfill letter and a Photo/Video Cert form on file to close permit. Waiting for you to upload them
PRPL202106782	1036	1801 Spring Ave, Carrollton, Tx 75006	PRC200000 - Plumbing Work Final	13000	Gregory Smith	Passed	
	4021		PRC200122 - Water Heater Final	13600	Gregory Smith	Passed	
PRPL202106804	1036	1103 Jeanette Way, Carrollton, Tx 75006	PRC200000 - Plumbing Work Final	13000	Gregory Smith	Passed	
PRPL202106844		2015 Brentwood Ln, Carrollton, Tx 75006	PRC200000 - Plumbing Work Final	13001	Gregory Smith	Passed	
PRPL202106852	4021	3137 Barton Rd, Carrollton, Tx 75007	PRC200122 - Water Heater Final	13600	Gregory Smith	Not Ready	A Photo/Video Cert form must be completed and uploaded when submitting pictures. Please upload to close the permit.
PRPL202106883		4145 Cobblestone Dr, Carrollton, Tx 75007	PRC200122 - Water Heater Final	13600	Gregory Smith	Passed	
PRPL202106890	1036	1824 Auburn Dr, Carrollton, Tx 75007	PRC200000 - Plumbing Work Final	13000	Gregory Smith	Passed w/ Notes	Must have a signed Under Slab Backfill Letter and a Photo/Video Cert form on file to close permit. Please upload TODAY. Inspection approved.



CARROLLTON  
TEXAS

DAILY INSPECTION RESULTS  
As of Tuesday, October 26, 2021 12:00 PM

Permit Number	Phone Sys. Num.	Street Address	Inspection Code - Description	Insp. Num.	Inspector Name	Inspection Results	Inspection Result Comment
	1034		PRC200148 - Under Slab Excavation/Backfill Verification	9800	Gregory Smith	Passed	
PRPL202106892	1036	1902 Vista Oaks Dr, Carrollton, Tx 75007	PRC200000 - Plumbing Work Final	13000	Gregory Smith	Passed	
	1034		PRC200148 - Under Slab Excavation/Backfill Verification	9800	Lisa Cheek	Passed	under slab letter uploaded along with compaction letter
PRPL202106913	1036	1541 Bastrop Dr, Carrollton, Tx 75010	PRC200000 - Plumbing Work Final	13000	Gregory Smith	Passed w/ Notes	Must have an Under Slab Backfill letter on file to close permit. For assistance with this, contact a permit tech at our service desk. Inspection approved.
	1034		PRC200148 - Under Slab Excavation/Backfill Verification	9800	Lisa Cheek	Passed	Under slab letter uploaded
PRPL202106924	1036	2125 Hunters Ridge, Carrollton, Tx 75006	PRC200000 - Plumbing Work Final	13000	Gregory Smith	Passed w/ Notes	Must have a completed Under Slab Backfill letter on file to close permit. Please upload TODAY. Inspection approved.
PRPL202106928		2601 Fallcreek Dr, Carrollton, Tx 75006	PRC200000 - Plumbing Work Final	13000	Gregory Smith	Not Ready	Must have pictures of work for inspection along with a Photo/Video Cert form. If you went under the slab of the home, we will also need a signed Under Slab Backfill letter on file from you. For assistance with this process, please speak with a permit tech at our service desk today.
PRRE202105315	1010	2100 Austin Dr, Carrollton, Tx 75006	PRC200042 - Electrical Service	6700	David C. Garcia	Failed	
PRRE202105776	3010	2321 Stallion St, Carrollton, Tx 75010	PRC200105 - Solar Panel Electrical Rough	12100	David C. Garcia	Failed	1.electrician not on site
	6010		PRC200106 - Solar System Final	12200	David C. Garcia	Failed	1.electrician not on site
PRRE202106520	3010	2217 Ridgedale Dr, Carrollton, Tx 75006	PRC200105 - Solar Panel Electrical Rough	12301	David C. Garcia	Failed	no Electrician on site
	6010		PRC200106 - Solar System Final	12401	David C. Garcia	Failed	no Electrician on site
PRRN202005882	3011	2528 Old Denton Rd, Suite:330, Carrollton, Tx 75006	PRC200027 - Electrical Rough Ceiling-Commercial	1400	Michael Serna	Passed	
PRRN202104421	3040	2810 E Trinity Mills Rd, Suite:237, Carrollton, Tx 75006	PRC200025 - Building Framing-Commercial	1900	Michael Serna	Partial Pass	Partial pass for wall that will hold the vent in the kitchen area. Contractor wishes to hang concrete wall board prior to vent hood.
	1902		PRC200093 - Pre-Pour/Foundation-Commercial	900	Michael Serna	Passed	
PRRN202105459	3011	3030 N Josey Ln, Suite:130, Carrollton, Tx 75007	PRC200027 - Electrical Rough Ceiling-Commercial	1400	Michael Serna	Not Ready	Cancelled by contractor



CARROLLTON  
TEXAS

DAILY INSPECTION RESULTS  
As of Tuesday, October 26, 2021 12:00 PM

Permit Number	Phone Sys. Num.	Street Address	Inspection Code - Description	Insp. Num.	Inspector Name	Inspection Results	Inspection Result Comment
PRRN202106079	1902	3044 Old Denton Rd, Suite:133, Carrollton, Tx 75007	PRC200093 - Pre-Pour/Foundation-Commercial	900	Michael Serna	Failed	Pipes not wrapped
PRSF202100532	4062	1745 Clem Castle Dr, Carrollton, Tx 75010	PRC200041 - Electrical/Energy Final-Residential	3201	Thomas Schenkelberg	Passed w/ Notes	1. Appliances not installed. 2. Missing back splash where electrical devices are installed. 3. Missing energy sticker at electrical panel.
PRSF202100712	1056	4237 Mingo Dr, Carrollton, Tx 75010	PRC200120 - Walk & Approach/Residential	4101	Michael Serna	Passed	
	2001		PRC200155 - Engineer's Letter-Residential	4600	Lisa Cheek	Passed	engineer's letter uploaded
PRSF202100714	1056	4241 Mingo Dr, Carrollton, Tx 75010	PRC200120 - Walk & Approach/Residential	4101	Michael Serna	Passed	
	2001		PRC200155 - Engineer's Letter-Residential	4600	Lisa Cheek	Passed	eng letter uploaded
PRSF202100717	1056	4245 Mingo Dr, Carrollton, Tx 75010	PRC200120 - Walk & Approach/Residential	4101	Michael Serna	Passed	
	2001		PRC200155 - Engineer's Letter-Residential	4600	Lisa Cheek	Passed	eng letter uploaded
PRSF202100720	1056	4249 Mingo Dr, Carrollton, Tx 75010	PRC200120 - Walk & Approach/Residential	4101	Michael Serna	Passed	
	2001		PRC200155 - Engineer's Letter-Residential	4600	Lisa Cheek	Passed	eng letter uploaded
PRSF202100834	4063	1720 Dame Lori Ln, Carrollton, Tx 75010	PRC200023 - Building/Energy Final-Residential	4400	Thomas Schenkelberg	Failed	master bathroom shower enclosure is incomplete
PRSF202101011	3067	1729 Sir Dustin Ln	PRC200065 - Insulation/Envelope Seal-Residential	2200	Thomas Schenkelberg	Passed	
PRSF202101120		1732 Sir Dustin Ln	PRC200065 - Insulation/Envelope Seal-Residential	2200	Thomas Schenkelberg	Passed	
PRSF202101150	1056	4913 White Lion Ln	PRC200120 - Walk & Approach/Residential	4102	Thomas Schenkelberg	Passed	
PRSF202101151		1749 Sir Dustin Ln	PRC200120 - Walk & Approach/Residential	4103	Thomas Schenkelberg	Passed	
PRSF202101152	3067	1725 Sir Dustin Ln	PRC200065 - Insulation/Envelope Seal-Residential	2200	Thomas Schenkelberg	Passed	
PRSF202101352	1056	1764 Lady Bettye Dr	PRC200120 - Walk & Approach/Residential	4100	Thomas Schenkelberg	Passed	
PRSF202101611	3067	4940 White Lion Ln	PRC200065 - Insulation/Envelope Seal-Residential	2200	Thomas Schenkelberg	Passed	
PRSF202101850		1733 Sir Dustin Ln	PRC200065 - Insulation/Envelope Seal-Residential	2200	Thomas Schenkelberg	Passed	



**CARROLLTON**  
TEXAS

## DAILY INSPECTION RESULTS

As of Tuesday, October 26, 2021 12:00 PM

Permit Number	Phone Sys. Num.	Street Address	Inspection Code - Description	Insp. Num.	Inspector Name	Inspection Results	Inspection Result Comment
PRSF202101868	3064	4928 Sir Casey Ct, Carrollton, Tx 75010	PRC200040 - Electrical Rough/Energy-Residential	1601	Thomas Schenkelberg	Passed w/ Notes	prior inspectors requirements met
	3063		PRC200061 - Hvac Rough/Energy- Residential	1301	Thomas Schenkelberg	Passed w/ Notes	prior inspectors requirements met
PRSF202101896	3066	4908 Sir Cole Ct	PRC200022 - Building Framing- Residential	2000	Thomas Schenkelberg	Passed	
PRSF202102114	1056	1737 Sir Dustin Ln	PRC200120 - Walk & Approach/Residential	4100	Thomas Schenkelberg	Passed	
PRSF202102473	3064	4813 Cumberland Cir, Carrollton, Tx 75010	PRC200040 - Electrical Rough/Energy-Residential	1600	Thomas Schenkelberg	Failed	220 line in NM Box, internal clamp is broken all the way off
	3063		PRC200061 - Hvac Rough/Energy- Residential	1300	Thomas Schenkelberg	Failed	no attic access
PRSF202102684	1056	4817 Iron Club Ln, Carrollton, Tx 75010	PRC200120 - Walk & Approach/Residential	4101	Thomas Schenkelberg	Passed	
PRSF202102711	3066	1768 Dartmoor Dr, Carrollton, Tx 75010	PRC200022 - Building Framing- Residential	2002	Thomas Schenkelberg	Passed	
PRSF202102730		1724 Dartmoor Dr, Carrollton, Tx 75010	PRC200022 - Building Framing- Residential	2000	Thomas Schenkelberg	Passed	
PRSF202102752	3067	1760 Dame Lori Ln, Carrollton, Tx 75010	PRC200065 - Insulation/Envelope Seal-Residential	2200	Thomas Schenkelberg	Passed	
PRSF202103057	3066	1749 Dartmoor Dr, Carrollton, Tx 75010	PRC200022 - Building Framing- Residential	2000	Thomas Schenkelberg	Failed	1. poly seal all top plate penetrations 2. fire rating on all electrical junctions from garage to habitable areas 3. missing straps at side and back of dwelling.
PRSF202103058		1740 Lady Bettye Dr, Carrollton, Tx 75010	PRC200022 - Building Framing- Residential	2002	Thomas Schenkelberg	Partial Pass	
PRSF202103338	3064	4921 Sir Casey Ct, Carrollton, Tx 75010	PRC200040 - Electrical Rough/Energy-Residential	1600	Thomas Schenkelberg	Passed	
	3063		PRC200061 - Hvac Rough/Energy- Residential	1300	Thomas Schenkelberg	Failed	1. duct and register hanging in dinning room area. 2. no 2nd floor attic access
PRSF202103339	3066	1748 Lady Bettye Dr, Carrollton, Tx 75010	PRC200022 - Building Framing- Residential	2002	Thomas Schenkelberg	Passed	
PRSG202105634	4041	1600 Marsh Ln, Suite:108, Carrollton, Tx 75006	PRC200102 - Sign Final w/ Electrical (If Any)	11800	David C. Garcia	Passed	
PRSG202105881		1445 Mac Arthur Dr, Carrollton, Tx 75007	PRC200102 - Sign Final w/ Electrical (If Any)	11800	David C. Garcia	Passed	
PRTU202106803	6015	1510 Randolph St, Suite:105, Carrollton, Tx 75006	PRC200038 - Electrical Service/Construction Heat/Clean & Show	2600	David C. Garcia	Passed	