

Fire Lane Paving Inspection Checklist
General Design Standard
Sections 2, 10
P20 Standard Design

- Line locates
- Concrete cutting or sawing
- Excavation
- Concrete pavement per GDS
- Reinforcing
- Final grading
- Striping
- Fire lane shall be minimum 24' wide
- Required minimum inside curb radius shall be 20'
- Pavement saw-cutting must be done within 5-12 hours of pouring